

SUMMER 2022 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT 11 APS LOCATIONS

(LATEST BATCH IN ROTATING THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)

Collect Date	Location	Param	In Parts/Billion - PPB	
			EPA 200.8	Result
6/9/2022	Arlington Community High School - 1st Floor Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Arlington Community High School - 2nd Floor Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Cardinal Elementary - Cafeteria Bottle Filler	Lead	EPA 200.8	ND
6/9/2022	Cardinal Elementary - Cafeteria Bottle Filler by Rm #136	Lead	EPA 200.8	ND
6/9/2022	Career Center - 1st Floor Bottle Filler	Lead	EPA 200.8	ND
6/9/2022	Career Center - 2nd Floor Bottle Filler by Rm #211	Lead	EPA 200.8	ND
6/9/2022	Discovery Elementary - Bottle Filler at Rm #100	Lead	EPA 200.8	ND
6/9/2022	Discovery Elementary - Kitchen Sink	Lead	EPA 200.8	ND
6/9/2022	Facilities - Bottle filler Main Floor @ Main Door	Lead	EPA 200.8	ND
6/9/2022	Facilities - Bottle filler Lower Floor @ Grounds Shop	Lead	EPA 200.8	0.0004
6/9/2022	Hamm Middle - Bottle filler by Rm #228	Lead	EPA 200.8	ND
6/9/2022	Hamm Middle - Bottle filler by Rm #329	Lead	EPA 200.8	ND
6/9/2022	Hamm Middle - Bottle filler by Rm #112A	Lead	EPA 200.8	ND
6/9/2022	Kenmore Middle - Gym Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Kenmore Middle - Cafeteria Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Kenmore Middle - Bottle filler by Rm #377	Lead	EPA 200.8	ND
6/9/2022	Langston by Rm #115	Lead	EPA 200.8	ND
6/9/2022	Langston - Kitchen Sink	Lead	EPA 200.8	ND
6/9/2022	Wakefield High - Bottle filler outside Cafeteria	Lead	EPA 200.8	ND
6/9/2022	Wakefield High - Bottle filler on 2nd Floor outside B/G Rest Rooms	Lead	EPA 200.8	ND
6/9/2022	Washington Liberty High - By Rm #1008	Lead	EPA 200.8	ND
6/9/2022	Washington Liberty High - By Rm #1600	Lead	EPA 200.8	ND
6/9/2022	Yorktown High - Rm #140F	Lead	EPA 200.8	ND
6/9/2022	Yorktown High - Kitchen Sink	Lead	EPA 200.8	0.0005
NB: All but two are at None Detected (ND) those two are at miniscule traces. Actionable level is 15.00 PPB				
Any questions on these results can be directed to Jim Meikle, Director of Maintenance APS - 703 228 6617				